



Access Compliance Report - Public Rights-of-Way
(Corridor: Sidewalk & Intersection Items)

Corridor ID: CORONEL_RD_001



ADA Survey Summary

Item	Description	Quantity	EA
1	Vertical Displacement <= 1"	36	EA
2	Vertical Displacement > 1"	0	EA
3	Uneven Vertical Displacement	0	EA
4	Horizontal Opening > 0.5"	1	EA
5	Poor Surface Condition	39	SY
6	Utility Obstruction	0	EA
7	Power Pole Obstruction	0	EA
8	Traffic Signal Obstruction	0	EA
9	Sign Obstruction	0	EA
10	Low Vegetative Obstruction	0	EA
11	Overhead Vegetative Obstruction	0	EA
12	Other Obstruction*	0	EA
13	Miscellaneous Obstruction	0	EA
14	Temp/Private Obstruction	0	EA
15	Commercial Driveway	96	LF
16	Residential Driveway	40	LF
17	Total Sidewalk Length Assessed	1734	LF
18	Average Sidewalk Width	91	IN
19	Curb Ramps In Corridor	1	EA
20	Island Curb Cuts In Corridor	0	EA
21	Signal Push Buttons In Corridor	0	EA
22	Accessible Parking Spaces In Corridor	0	EA
23	Missing Sidewalk/Gaps in Connectivity	0	LF
24	Buried/Narrow Sidewalk	0	LF
25	Sidewalk Not Surveyed	143	LF
26	No Sidewalk Observed	0	LF
27	Corridor Severity Score	31.16	

Google Street View Link

http://www.google.com/maps/@?api=1&map_action=pano&viewpoint=33.76724476,-117.78579459

Inventory Symbology	
Running Slope (Aligned, Not Costed)	
5.1 – 8.3%	
8.4 – 10.0%	
10.1 – 12.5%	
12.5%+	
Collection in Adjacent Corridors	
Curb Ramps	
Island Curb Cuts	
Signal Push Buttons	
Sidewalk Collection	

ADA Compliance Cost Estimate **

Item	Description	Quantity	Unit	Unit Price	Item Cost
1	Vertical Displacement <= 1"	14	EA	\$150.00	\$ 2100.00
2	Vertical Displacement > 1"	0	EA	\$2125.00	\$ 0.00
3	Uneven Vertical Displacement	0	EA	\$2125.00	\$ 0.00
4	Horizontal Opening > 0.5"	0	EA	\$1062.00	\$ 0.00
5	Poor Surface Condition	6	SY	\$255.50	\$ 1584.00
6	Utility Obstruction	0	EA	\$5000.00	\$ 0.00
7	Power Pole Obstruction	0	EA	\$20000.00	\$ 0.00
8	Traffic Signal Obstruction	0	EA	\$5000.00	\$ 0.00
9	Sign Obstruction	0	EA	\$2000.00	\$ 0.00
10	Low Vegetative Obstruction	0	EA	\$200.00	\$ 0.00
11	Overhead Vegetative Obstruction	0	EA	\$400.00	\$ 0.00
12	Other Obstruction*	0	EA	\$2000.00	\$ 0.00
13	Miscellaneous Obstruction	0	EA	\$2000.00	\$ 0.00
14	Commercial Driveway	96	LF	\$118.00	\$ 11437.00
15	Residential Driveway	24	LF	\$118.00	\$ 2885.00
16	Running Slope Violation	0	SY	\$255.50	\$ 0.00
17	Cross Slope Violation	178	SY	\$255.50	\$ 45523.00
18	Running and Cross Slope violations	632	SY	\$255.50	\$ 161600.00
19	Non-Compliant Curb Ramps and Total Cost*	1	EA	VARIES	\$ 3332.00
20	Non-Compliant Island Curb Cuts and Total Cost*	0	EA	VARIES	\$ 0.00
21	Non-Compliant Signal Push Buttons Cuts and Total Cost*	0	EA	VARIES	\$ 0.00
22	Non-Compliant Accessible Parking Spaces and Total Cost*	0	EA	VARIES	\$ 0.00
23	Missing Sidewalk/Gap in Connectivity	0	SY	\$150.00	\$ 0.00
24	Buried/Narrow Sidewalk	0	SY	\$255.50	\$ 0.00

Total: \$ \$228,463.00

Compliance Symbology	
Compliant Curb Ramp	
Non-Compliant Curb Ramp	
Compliant Island Curb Cut	
Non-Compliant Island Curb Cut	
Compliant Signal	
Non-Compliant Signal	
Cross Slope	
2.01 - 3.0%	
3.01 - 4.0%	
4.01 - 5.0%	
5.01%+	
Running Slope (Deviated, Costed)	
5.1 – 8.3%	
8.4 – 10.0%	
10.1 – 12.5%	
12.5%+	

*Note: Some items combined for display. See Unit Cost Table for specific unit costs for each type of obstruction, curb ramp, island curb cut. Missing sidewalk/gaps in connectivity reported together in compliance report and are separate in the GIS layers.
**Note: ADA pedestrian issues have been identified and quantified in the ADA Survey Summary. There are instances where multiple issues can be resolved with a single corrective measure. The ADA Compliance Cost Estimate reflects the best estimation of quantities and cost to resolve all identified ADA issues.