



Access Compliance Report Public Rights-of-Way (Island Curb Cuts)



Main Street: O_NEILL_DR Cross Street: DORRANCE_DR Location: N

ADA ID: CCRK211102132513 Curb Cut Type: MedianRefuge2 Initial Pass/Fail: Pass Overall Compliance: No Severity Score: 15

Codes/Mitigation Info/Possible Solution Field Measurements/Component Compliance



Possible Solutions:
Install Detectable Warning System.

Surveyor Notes:
N/A

OC Std/PROW:
R305, STD 1115

Total Cost: \$ 1200

Parcel ID Number 759-621-01

Google Street View Link
http://www.google.com/maps/@?api=1&map_action=pano&viewpoint=33.55514074,-117.64509725

Street 1 Name O_NEILL_DR
Stop Condition-Street 1 N/A
Street 2 Name DORRANCE_DR
Stop Condition-Street 2 N/A

Compliance	Description	Data	Compliance	Description	Data
Yes	Refuge 1 Length (In)	55	Yes	Guttter 1 Ponding	No
Yes	Refuge 1 Width (In)	96	Yes	Gutter 1 Lip Ht (In)	0
Yes	Refuge 1 Slope (%)	3.5	Yes	Gutter 1 Slope (%)	4.4
Yes	Refuge 1 Cross Slope (%)	2.1	Yes	Gutter 1 Cross Slope (%)	2.1
N/A	Painted Cross Walk 1	Yes	No	DWS 1 Provided	No
	Cross Walk 1 Direction	W	N/A	DWS 1 Contrast	N/A
	Cross Walk 1 Width (In)	144	N/A	DWS 1 Length (In)	N/A
Yes	Refuge Inside Cross Walk 1	Yes	N/A	DWS 1 Full Width	N/A
	Road 1 Slope (%)	9.2	N/A	DWS 1 Offset (In)	N/A
	Road 1 Cross Slope (%)	1.2			N/A
Yes	Refuge 2 Length (In)	93	Yes	Guttter 2 Ponding	No
Yes	Refuge 2 Width (In)	96	Yes	Gutter 2 Lip Ht (In)	0
Yes	Refuge 2 Slope (%)	0.3	Yes	Gutter 2 Slope (%)	2.6
Yes	Refuge 2 Cross Slope (%)	2.2	Yes	Gutter 2 Cross Slope (%)	0.3
N/A	Painted Cross Walk 2	Yes	No	DWS 2 Provided	No
	Cross Walk 2 Direction	E	N/A	DWS 2 Contrast	N/A
	Cross Walk 2 Width (In)	144	N/A	DWS 2 Length (In)	N/A
Yes	Refuge Inside Cross Walk 2	Yes	N/A	DWS 2 Full Width	N/A
	Road 2 Slope (%)	4.4	N/A	DWS 2 Offset (In)	N/A
	Road 2 Cross Slope (%)	2.1			
Yes	Overall Surface Condition:	Acceptable			

Obstruction and Utility Measurement/Component Compliance

Compliance	Description	Data	Compliance	Description	Data
Yes	Obstructions Present?	No	N/A	Utilities Present?	No
	Obstruction Types	N/A		Utility Types	
	Obstruction Dimensions	N/A			N/A

