




Access Compliance Report Public Rights-of-Way (Island Curb Cuts)



Main Street: ANDAZA_ST		Cross Street: ANDAZA_ST		Location:	W
ADA ID: CCRK211129123855	Curb Cut Type: MedianRefuge2	Initial Pass/Fail: Pass	Overall Compliance: No	Severity Score:	10
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		



Possible Solutions:

Remove & Replace Gutter.

Surveyor Notes:

N/A

OC Std/PROW:

R304.5.4, R304.5.3, STD 1115

Total Cost:

\$ 252

Parcel ID Number

755-351-04

Street 1 Name

ANDAZA_ST

Stop Condition-Street 1

N/A

Street 2 Name

ANDAZA_ST

Stop Condition-Street 2

N/A

Google Street View Link

http://www.google.com/maps/@?api=1&map_action=pano&viewpoint=33.5336207,-117.60147418

Compliance	Description	Data	Compliance	Description	Data
Yes	Refuge 1 Length (In)	60	Yes	Guttter 1 Ponding	No
Yes	Refuge 1 Width (In)	96	Yes	Gutter 1 Lip Ht (In)	0
Yes	Refuge 1 Slope (%)	0.4	Yes	Gutter 1 Slope (%)	2.4
Yes	Refuge 1 Cross Slope (%)	1.2	Yes	Gutter 1 Cross Slope (%)	0.7
N/A	Painted Cross Walk 1	Yes	Yes	DWS 1 Provided	Yes
	Cross Walk 1 Direction	N	Yes	DWS 1 Contrast	Yes
	Cross Walk 1 Width (In)	144	Yes	DWS 1 Length (In)	36
Yes	Refuge Inside Cross Walk 1	Yes	Yes	DWS 1 Full Width	Yes
	Road 1 Slope (%)	0.9	Yes	DWS 1 Offset (In)	0
	Road 1 Cross Slope (%)	1.4			N/A
Yes	Refuge 2 Length (In)	60	Yes	Guttter 2 Ponding	No
Yes	Refuge 2 Width (In)	96	Yes	Gutter 2 Lip Ht (In)	0
Yes	Refuge 2 Slope (%)	1.6	No	Gutter 2 Slope (%)	7.6
Yes	Refuge 2 Cross Slope (%)	2.8	No	Gutter 2 Cross Slope (%)	3
N/A	Painted Cross Walk 2	Yes	Yes	DWS 2 Provided	Yes
	Cross Walk 2 Direction	S	Yes	DWS 2 Contrast	Yes
	Cross Walk 2 Width (In)	144	Yes	DWS 2 Length (In)	36
Yes	Refuge Inside Cross Walk 2	Yes	Yes	DWS 2 Full Width	Yes
	Road 2 Slope (%)	4.4	Yes	DWS 2 Offset (In)	0
	Road 2 Cross Slope (%)	3.8			
Yes	Overall Surface Condition: Acceptable				

Obstruction and Utility Measurement/Component Compliance

Compliance	Description	Data	Compliance	Description	Data
Yes	Obstructions Present?	No	N/A	Utilities Present?	No
	Obstruction Types	N/A		Utility Types	
	Obstruction Dimensions	N/A			N/A

