



Access Compliance Report Public Rights-of-Way (Curb Ramps)



Main Street: LAMBERT_RD		Cross Street: VALENCIA_AVE		Location:	SW
ADA ID: RPAT210920101415	Ramp Type:Type 1 - Perpendicular	Initial Pass/Fail: Pass	Overall Compliance: No	Severity Score:	0

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	
---	--	---	--



Possible Solutions:

Remove & Replace Curb Slope. Utility Present.

Surveyor Notes:

N/A

OC Std/PROW:

R304.2.2, STD 1115

Total Cost: \$ 252

Parcel ID Number **320-071-29**
Ramp Island Or Median **None**
Ramp Orientation **NonDiag**
Google Street View Link:

Street 1 Name **LAMBERT_RD**
Stop Condition-Street 1 **Signal**
Street 2 Name **VALENCIA_AVE**
Stop Condition-Street 2 **N/A**

http://www.google.com/maps/@?api=1&map_action=pano&viewpoint=33.9239702,-117.84783564

Obstruction and Utility Measurement/Component Compliance

Compliance	Description	Data	Compliance	Description	Data
Yes	Obstructions Present?	No	N/A	Utilities Present?	Yes
	Obstruction Types	N/A		Utility Types	
	Obstruction Dimensions	N/A		Traffic Signal Pole	

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	93	N/A	Flare Type LT	
Yes	Ramp Width (in)	61			Sloped
Yes	Ramp Run Slope (%)	6.5	N/A	Flare Slope LT (%)	8.5
Yes	Ramp Cross Slope (%)	1.3	N/A	Flare Traversable LT	No
N/A	Landing Present	Yes	N/A	Flare Type RT	
N/A	Landing Length (in)	72			Sloped
Yes	Landing Width (in)	62	N/A	Flare Slope RT (%)	8.6
Yes	Landing Run Slope (%)	1.2	N/A	Flare Traversable RT	No
Yes	Landing Cross Slope (%)	1.3	Yes	DWS Provided	Yes
N/A	Landing Movement Obstructed?	No	Yes	DWS Contrast	Yes
	Landing Movement Type	N/A	Yes	DWS Length (in)	36
N/A	Landing Shared	No	Yes	DWS Full Width	Yes
N/A	Clear Space	N/A	Yes	DWS Offset Left (in)	0
N/A	Clear Space To Crosswalk (in)	N/A	Yes	DWS Offset Right (in)	N/A
N/A	Marked Crosswalk 1	Yes	N/A	Marked Crosswalk 2	N/A
	Crossing 1 Direction	N		Crossing 2 Direction	N/A
	Marked Crosswalk 1 Width (in)	120		Marked Crosswalk 2 Width (in)	N/A
Yes	Ramp Inside Crosswalk 1	Yes	Yes	Ramp Inside Crosswalk 2	N/A
	Crossing 1 Slope (%)	5		Crossing 2 Slope (%)	N/A
	Crossing 1 Cross Slope (%)	3.7		Crossing 2 Cross Slope (%)	N/A
Yes	Gutter Ponding	No	No	Curb Slope	10.1
Yes	Gutter Lip Height (in)	0		Road Run Slope (%)	N/A
Yes	Gutter Run Slope (%)	2.3		Road Cross Slope (%)	N/A
Yes	Gutter Cross Slope (%)	0.3			
Yes	Overall Surface Condition: Acceptable		Yes	Perp Joint Present	Yes
	Cross Gutter Present?	No		Spandrel Present?	No
	Replace Cross Gutter?	N/A		Replace Spandrel?	N/A

