



Access Compliance Report Public Rights-of-Way (Curb Ramps)



Main Street: RANCHO_SANTIAGO_BLVD		Cross Street: PEARL_ST		Location:	SW
ADA ID: RPAT210928102250	Ramp Type: Type 4 - Parallel	Initial Pass/Fail: Pass	Overall Compliance: No	Severity Score:	25
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		



Possible Solutions:

Remove & Replace Curb Slope. Remove & Replace Gutter. Relocate Obstruction.

Surveyor Notes:

N/A

OC Std/PROW:

R304.2.2, R304.5.4, R304.5.3, R302.3, R402.2, STD 1115

Total Cost: \$ 5504

Parcel ID Number **383-272-06**
Ramp Island Or Median **None**
Ramp Orientation **Diag**
Google Street View Link:

Street 1 Name **RANCHO_SANTIAGO_BLVD**
Stop Condition-Street 1 **NoControl**
Street 2 Name **PEARL_ST**
Stop Condition-Street 2 **StopSign**

http://www.google.com/maps/@?api=1&map_action=pano&viewpoint=33.78858642,-117.80143372

Obstruction and Utility Measurement/Component Compliance

Compliance	Description	Data	Compliance	Description	Data
No	Obstructions Present?	Yes	N/A	Utilities Present?	No
	Obstruction Types	Power Pole		Utility Types	
	Obstruction Dimensions	N/A			N/A



Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length LT (in)	120	N/A	Ramp Length RT (in)	83
Yes	Ramp Width LT (in)	59	Yes	Ramp Width RT (in)	57
Yes	Ramp Run Slope LT (%)	8.2	Yes	Ramp Run Slope RT (%)	5.7
Yes	Ramp Cross Slope LT (%)	0.4	Yes	Ramp Cross Slope RT (%)	0.5
N/A	Landing Present	Yes	Yes	DWS Provided	Yes
N/A	Landing Length (in)	58	Yes	DWS Contrast	Yes
Yes	Landing Width (in)	48	Yes	DWS Length (in)	36
Yes	Landing Run Slope (%)	0.3	Yes	DWS Full Width	Yes
Yes	Landing Cross Slope (%)	1.6		DWS Offset Type	Single
N/A	Landing Movement Obstructed?	No	Yes	DWS Offset Left (in)	0
	Landing Movement Type	Curb	Yes	DWS Offset Right (in)	N/A
N/A	Landing Shared	No			
N/A	Clear Space	Yes			
N/A	Clear Space To Crosswalk (in)	48			
N/A	Marked Crosswalk 1	No	N/A	Marked Crosswalk 2	No
	Crossing 1 Direction	E		Crossing 2 Direction	N
	Marked Crosswalk 1 Width (in)	N/A		Marked Crosswalk 2 Width (in)	N/A
N/A	Ramp Inside Crosswalk 1	N/A	N/A	Ramp Inside Crosswalk 2	N/A
	Crossing 1 Slope (%)	5.3		Crossing 2 Slope (%)	1.1
	Crossing 1 Cross Slope (%)	3.1		Crossing 2 Cross Slope (%)	7.1
Yes	Gutter Ponding	No	No	Curb Slope	10
Yes	Gutter Lip Height (in)	0		Road Run Slope (%)	3.9
No	Gutter Run Slope (%)	9.5		Road Cross Slope (%)	2.3
No	Gutter Cross Slope (%)	4.2	Yes	Perpendicular Joint Present	Yes
Yes	Overall Surface Condition	Acceptable			
	Cross Gutter Present?	No		Spandrel Present?	No
	Replace Cross Gutter?	N/A		Replace Spandrel?	N/A