



Access Compliance Report Public Rights-of-Way (Curb Ramps)




Main Street: N/A Cross Street: CRAWFORD_CANYON_RD Location: SW

ADA ID: RPAT220301120359 Ramp Type: Type 6 - Directional 1 Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 0

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

N/A

OC Std/PROW:

STD 1115

Total Cost: \$ 3080

Parcel ID Number 393-462-12
Ramp Island Or Median None
Ramp Orientation NonDiag
Google Street View Link:

http://www.google.com/maps/@?api=1&map_action=pano&viewpoint=33.78393843,-117.7959111

Street 1 Name N/A
Stop Condition-Street 1 NoControl
Street 2 Name CRAWFORD_CANYON_RD
Stop Condition-Street 2 N/A

Obstruction and Utility Measurement/Component Compliance

Compliance	Description	Data	Compliance	Description	Data
Yes	Obstructions Present?	No	N/A	Utilities Present?	No
	Obstruction Types	N/A		Utility Types	N/A
	Obstruction Dimensions	N/A			N/A

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	78	N/A	Flare Type LT	
Yes	Ramp Width (in)	60			Sloped
Yes	Ramp Run Slope (%)	3.3	N/A	Flare Slope LT (%)	3.3
Yes	Ramp Cross Slope (%)	1.5	N/A	Flare Traversable LT	Yes
N/A	Grade Break	Yes	N/A	Flare Type RT	
N/A	Grade Break Slope (%)	1.2			Curbed2
N/A	Grade Break Cross Slope (%)	2	N/A	Flare Slope RT (%)	N/A
	Addl Para Ramp Left?	No	N/A	Flare Traversable RT	N/A
	Addl Para Ramp Right?	No	N/A	DWS Provided	Yes
N/A	Landing Present	Yes	N/A	DWS Contrast	Yes
N/A	Landing Length (in)	75	N/A	DWS Length (in)	36
N/A	Landing Width (in)	66	N/A	DWS Full Width	Yes
N/A	Landing Run Slope (%)	3.6		DWS Offset Type	Multiple
N/A	Landing Cross Slope (%)	1.8	N/A	DWS Left Offset (in)	0
N/A	Landing Movement Obstructed?	No	N/A	DWS Right Offset (in)	36
	Landing Movement Type	N/A			
N/A	Landing Shared	No			
N/A	Marked Crosswalk 1	No	N/A	Clear Space	N/A
	Crossing 1 Direction	N	N/A	Clear Space To Crosswalk (in)	N/A
	Marked Crosswalk 1 Width (in)	N/A			
N/A	Ramp Inside Crosswalk 1	N/A			
	Crossing 1 Slope (%)	4			
	Crossing 1 Cross Slope (%)	2.9			
N/A	Gutter Ponding	No	Yes	Curb Slope	0.8
Yes	Gutter Lip Height (in)	0		Road Run Slope (%)	N/A
N/A	Gutter Run Slope (%)	N/A		Road Cross Slope (%)	N/A
N/A	Gutter Cross Slope (%)	N/A		Parallel Ramp Side	N/A
Yes	Overall Surface Condition	Acceptable	Yes	Perp Joint Present	Yes
	Cross Gutter Present?	Yes		Spandrel Present?	No
	Replace Cross Gutter?	No		Replace Spandrel?	N/A

