

## **Access Compliance Report Public Rights-of-Way** (Curb Ramps)



SE

Location:

Main Street: BIMINI\_DR **Cross Street: LA LIMONAR DR** 

ADA ID: RPRK211013133552 Ramp Type:Type 1 - Perpendicular Diagonal Initial Pass/Fail: Pass **Overall Compliance: No Severity Score:** 20

## **Codes/Mitigation Info/Possible Solution**



Remove & Replace Curb Ramp With Two New **Directional Ramps or Equivalent.** 

R204.3, R304.2.1, R304.2.2-Perp, R304.3.2-Para, R304.5.3, R305, STD 1115

6160

Parcel ID Number	503-514-25	Street 1 Name	BIMINI_DR
Ramp Island Or Median	None	Stop Condition-Street 1	StopSign
Ramp Orientation	Diag	Street 2 Name	LA_LIMONAR_DR
Google Street View Link:		Stop Condition-Street 2	NoControl

http://www.google.com/maps/@?api=1&map\_action=pano&viewpoint=33.7681339,-117.79029526

## **Obstruction and Utility Measurement/Component Compliance**

Com	pliance Description	Data	Com	pliance Description	<u>Data</u>
Yes	Obstructions Present?	No	N/A	Utilities Present?	No
	Obstruction Types	N/A		Utility Types	
	Obstruction Dimensions	N/A			N/A



Field Measurements/Component Compliance								
1	Com	pliance Description	Data	Com	pliance	Description	Data	
	N/A	Ramp Length (in)	128	N/A	Flare Typ	pe LT		
	Yes	Ramp Width (in)	48				Sloped	
	Yes	Ramp Run Slope (%)	4.6	N/A	Flare Slo	pe LT (%)	2.8	
	Yes	Ramp Cross Slope (%)	0.7	N/A	Flare Tra	versable LT	No	
	N/A	Landing Present	No	N/A	Flare Typ	pe RT		
	N/A	Landing Length (in)	N/A				Sloped	
	No	Landing Width (in)	N/A	N/A	Flare Slo	pe RT (%)	6.4	
	No	Landing Run Slope (%)	N/A	N/A	Flare Tra	versable RT	No	
	No	Landing Cross Slope (%)	N/A	No	DWS Pro	ovided	No	
	N/A	Landing Movement Obstructed?	No	N/A	DWS Co	ntrast	N/A	
		Landing Movement Type	N/A	N/A	DWS Le	ngth (in)	N/A	
	N/A	Landing Shared	N/A	N/A	DWS Fu	ll Width	N/A	
	N/A	Clear Space	Yes	N/A	DWS Off	set Left (in)	N/A	
	N/A	Clear Space To Crosswalk (in)	48	N/A	DWS Off	set Right (in)	N/A	
)	N/A	Marked Crosswalk 1	No	N/A	Marked (	Crosswalk 2	No	
		Crossing 1 Direction	NW		Crossing	2 Direction	SW	
2		Marked Crosswalk 1 Width (in)	N/A		Marked (	Crosswalk 2 Width (in)	N/A	
ı	N/A	Ramp Inside Crosswalk 1	N/A	Yes	Ramp In	side Crosswalk 2	N/A	
2		Crossing 1 Slope (%)	1.5		Crossing	2 Slope (%)	2.3	
١		Crossing 1 Cross Slope (%)	0.6		Crossing	2 Cross Slope (%)	1.6	
	Yes	Gutter Ponding	No	Yes	Curb Slo	ppe	3.6	
	Yes	Gutter Lip Height (in)	0		Road Ru	ın Slope (%)	0.6	
	Yes	Gutter Run Slope (%)	3		Road Cr	oss Slope (%)	0.6	
•	Yes	Gutter Cross Slope (%)	1.7					
'	Yes	Overall Surface Condition: Accep	ptable	No	Perp Joi	nt Present	No	
		Cross Gutter Present?	No		Spandre	Present?	No	
١		Replace Cross Gutter?	N/A		Replace	Spandrel?	N/A	