

ADA ID: RPRK211028131519

Access Compliance Report Public Rights-of-Way (Curb Ramps)



26

Severity Score:

 Main Street:
 NARROW_CANYON_RD
 Cross Street:
 N/A
 Location:
 SE

Initial Pass/Fail: Pass

Codes/Mitigation Info/Possible Solution Field Measurements/Com



Possible Solutions:

Remove & Replace Curb Ramp With Two New
Directional Ramps or Equivalent. Remove &
Replace Gutter.

Surveyor Notes:

Ramp Type: Type 4 - Parallel

N/A

OC Std/PROW:

R304.2.2, R204.3, R304.5.3, R304.2.1, R304.2.2-Perp, R304.3.2-Para, R305, R304.5.4, STD 1115

Total Cost: \$ 4252

Parcel ID Number	741-272-16
Ramp Island Or Median	None
Ramp Orientation	Diag
Google Street View Link:	

6 Street 1 Name NARROW_CANYON_RD
e Stop Condition-Street 1 NoControl
g Street 2 Name N/A
Stop Condition-Street 2 NoControl

http://www.google.com/maps/@?api=1&map action=pano&viewpoint=33.54801402,-117.64811403

Obstruction and Utility Measurement/Component Compliance

Compliance Description	Data Compliance Description	Data
Yes Obstructions Present?	No N/A Utilities Present?	No
Obstruction Types	N/A Utility Types	
Obstruction Dimensions	N/A	N/A



Field Measurements/Component Compliance								
	Compliance Description		Data	Com	pliance	Description	Data	
	N/A	Ramp Length LT (in)	139	N/A	Ramp Le	ength RT (in)	146	
	Yes	Ramp Width LT (in)	90	Yes	Ramp W	idth RT (in)	90	
	Yes	Ramp Run Slope LT (%)	7.7	Yes	Ramp R	un Slope RT (%)	3.2	
	Yes	Ramp Cross Slope LT (%)	1	No	Ramp C	ross Slope RT (%)	2.5	
	N/A	Landing Present	No	No	DWS Pr	ovided	No	
	N/A	Landing Length (in)	N/A	N/A	DWS Co	ontrast	N/A	
	No	Landing Width (in)	N/A	N/A	DWS Le	ngth (in)	N/A	
	No	Landing Run Slope (%)	N/A	N/A	DWS Fu	ll Width	N/A	
	No	Landing Cross Slope (%)	N/A		DWS Of	fset Type	N/A	
	N/A	Landing Movement Obstructed?	No	N/A	DWS Of	fset Left (in)	N/A	
		Landing Movement Type	Curb	N/A	DWS Of	fset Right (in)	N/A	
	N/A	Landing Shared	N/A					
	N/A	Clear Space	Yes					
	N/A	Clear Space To Crosswalk (in)	48					
2	N/A	Marked Crosswalk 1	No	N/A	Marked	Crosswalk 2	No	
		Crossing 1 Direction	N		Crossing	2 Direction	SW	
D		Marked Crosswalk 1 Width (in)	N/A		Marked	Crosswalk 2 Width (in)	N/A	
l	N/A	Ramp Inside Crosswalk 1	N/A	N/A	Ramp In	side Crosswalk 2	N/A	
A		Crossing 1 Slope (%)	3.8		Crossing	g 2 Slope (%)	2.9	
l		Crossing 1 Cross Slope (%)	2.6		Crossing	g 2 Cross Slope (%)	2.5	
	Yes	Gutter Ponding	No	No	Curb Slo	ppe	9.3	
	Yes	Gutter Lip Height (in)	0		Road Ru	ın Slope (%)	3.1	
_	No	Gutter Run Slope (%)	11.2		Road Cr	oss Slope (%)	0.3	
<u>a</u>	Yes	Gutter Cross Slope (%)	2.2	No	Perpend	icular Joint Present	No	
0	Yes	Overall Surface Condition Accep	ptable					
		Cross Gutter Present?	No		Spandre	el Present?	No	
A		Replace Cross Gutter?	N/A		Replace	Spandrel?	N/A	

Overall Compliance: No