



Access Compliance Report Public Rights-of-Way (Curb Ramps)



Main Street: VAGAR_ST Cross Street: AIROSO_ST Location: NE

ADA ID: RPRK211119142319 Ramp Type: Type 1 - Perpendicular Diagonal Initial Pass/Fail: Pass Overall Compliance: No Severity Score: 0

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

Remove & Replace Gutter.

Surveyor Notes:

N/A

OC Std/PROW:

R304.5.3, STD 1115

Total Cost:

\$ 252

Parcel ID Number 755-491-79

Ramp Island Or Median None

Ramp Orientation Diag

Google Street View Link:

http://www.google.com/maps/@?api=1&map_action=pano&viewpoint=33.54222119,-117.60084376

Street 1 Name VAGAR_ST

Stop Condition-Street 1 StopSign

Street 2 Name AIROSO_ST

Stop Condition-Street 2 NoControl

Obstruction and Utility Measurement/Component Compliance

Compliance	Description	Data	Compliance	Description	Data
Yes	Obstructions Present?	No	N/A	Utilities Present?	No
	Obstruction Types	N/A		Utility Types	
	Obstruction Dimensions	N/A			N/A

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	67	Yes	Flare Type LT	
Yes	Ramp Width (in)	62			Curbed2
Yes	Ramp Run Slope (%)	6.3	N/A	Flare Slope LT (%)	N/A
Yes	Ramp Cross Slope (%)	1.5	N/A	Flare Traversable LT	N/A
N/A	Landing Present	Yes	Yes	Flare Type RT	
N/A	Landing Length (in)	62			Curbed2
Yes	Landing Width (in)	78	N/A	Flare Slope RT (%)	N/A
Yes	Landing Run Slope (%)	2	N/A	Flare Traversable RT	N/A
Yes	Landing Cross Slope (%)	1.2	Yes	DWS Provided	Yes
N/A	Landing Movement Obstructed?	Yes	Yes	DWS Contrast	Yes
	Landing Movement Type	Curb	Yes	DWS Length (in)	36
N/A	Landing Shared	Yes	Yes	DWS Full Width	Yes
N/A	Clear Space	Yes	Yes	DWS Offset Left (in)	0
N/A	Clear Space To Crosswalk (in)	48	Yes	DWS Offset Right (in)	N/A
N/A	Marked Crosswalk 1	No	N/A	Marked Crosswalk 2	No
	Crossing 1 Direction	W		Crossing 2 Direction	S
	Marked Crosswalk 1 Width (in)	N/A		Marked Crosswalk 2 Width (in)	N/A
N/A	Ramp Inside Crosswalk 1	N/A	Yes	Ramp Inside Crosswalk 2	N/A
	Crossing 1 Slope (%)	3.1		Crossing 2 Slope (%)	2.1
	Crossing 1 Cross Slope (%)	2.3		Crossing 2 Cross Slope (%)	6.8
Yes	Gutter Ponding	No	Yes	Curb Slope	4.2
Yes	Gutter Lip Height (in)	0		Road Run Slope (%)	5.1
Yes	Gutter Run Slope (%)	4.9		Road Cross Slope (%)	3
No	Gutter Cross Slope (%)	4.8			
Yes	Overall Surface Condition: Acceptable		Yes	Perp Joint Present	Yes
	Cross Gutter Present?	No		Spandrel Present?	No
	Replace Cross Gutter?	N/A		Replace Spandrel?	N/A

