



Access Compliance Report Public Rights-of-Way (Curb Ramps)




Main Street: HUNTER_LN Cross Street: MADISON_AVE Location: NE

ADA ID: RPRK220203152543 Ramp Type: Type 4 - Parallel Initial Pass/Fail: Pass Overall Compliance: No Severity Score: 0

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

Remove & Replace Gutter.

Surveyor Notes:

N/A

OC Std/PROW:

R304.5.3, STD 1115

Total Cost: \$ 252

Parcel ID Number 097-472-10

Ramp Island Or Median None

Ramp Orientation Diag

Google Street View Link:

http://www.google.com/maps/@?api=1&map_action=pano&viewpoint=33.74807052,-117.97700799

Street 1 Name HUNTER_LN

Stop Condition-Street 1 StopSign

Street 2 Name MADISON_AVE

Stop Condition-Street 2 YieldSign

Obstruction and Utility Measurement/Component Compliance

Compliance	Description	Data	Compliance	Description	Data
Yes	Obstructions Present?	No	N/A	Utilities Present?	No
	Obstruction Types	N/A		Utility Types	
	Obstruction Dimensions	N/A			N/A

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length LT (in)	76	N/A	Ramp Length RT (in)	78
Yes	Ramp Width LT (in)	54	Yes	Ramp Width RT (in)	54
Yes	Ramp Run Slope LT (%)	8.2	Yes	Ramp Run Slope RT (%)	6.8
Yes	Ramp Cross Slope LT (%)	0.9	Yes	Ramp Cross Slope RT (%)	1
N/A	Landing Present	Yes	Yes	DWS Provided	Yes
N/A	Landing Length (in)	54	Yes	DWS Contrast	Yes
Yes	Landing Width (in)	48	Yes	DWS Length (in)	36
Yes	Landing Run Slope (%)	1.4	Yes	DWS Full Width	Yes
Yes	Landing Cross Slope (%)	1.2		DWS Offset Type	Single
N/A	Landing Movement Obstructed?	No	Yes	DWS Offset Left (in)	0
	Landing Movement Type	Curb	Yes	DWS Offset Right (in)	N/A
N/A	Landing Shared	No			
Yes	Clear Space	Yes			
Yes	Clear Space To Crosswalk (in)	48			
N/A	Marked Crosswalk 1	Yes	N/A	Marked Crosswalk 2	Yes
	Crossing 1 Direction	W		Crossing 2 Direction	S
	Marked Crosswalk 1 Width (in)	144		Marked Crosswalk 2 Width (in)	144
Yes	Ramp Inside Crosswalk 1	Yes	Yes	Ramp Inside Crosswalk 2	Yes
	Crossing 1 Slope (%)	1.4		Crossing 2 Slope (%)	6.3
	Crossing 1 Cross Slope (%)	0.5		Crossing 2 Cross Slope (%)	0.3
Yes	Gutter Ponding	No	Yes	Curb Slope	1.8
Yes	Gutter Lip Height (in)	0		Road Run Slope (%)	0
Yes	Gutter Run Slope (%)	1.8		Road Cross Slope (%)	1.1
No	Gutter Cross Slope (%)	2.2	Yes	Perpendicular Joint Present	Yes
Yes	Overall Surface Condition	Acceptable			
	Cross Gutter Present?	Yes		Spandrel Present?	Yes
	Replace Cross Gutter?	No		Replace Spandrel?	No

