



Access Compliance Report Public Rights-of-Way (Curb Ramps)



Main Street: ORANGE_AVE Cross Street: ORANGE_AVE Location: N

ADA ID: RPRK220218203654 Ramp Type: Type 1 - Perpendicular Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 0

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

N/A

OC Std/PROW:

STD 1115

Total Cost: \$ 3080

Parcel ID Number 127-112-20

Ramp Island Or Median None

Ramp Orientation NonDiag

Google Street View Link:

http://www.google.com/maps/@?api=1&map_action=pano&viewpoint=33.82506782,-117.96385927

Street 1 Name ORANGE_AVE

Stop Condition-Street 1 NoControl

Street 2 Name ORANGE_AVE

Stop Condition-Street 2 N/A

Obstruction and Utility Measurement/Component Compliance

Compliance	Description	Data	Compliance	Description	Data
Yes	Obstructions Present?	No	N/A	Utilities Present?	No
	Obstruction Types	N/A		Utility Types	
	Obstruction Dimensions	N/A			N/A

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	127	N/A	Flare Type LT	
Yes	Ramp Width (in)	48			Sloped
Yes	Ramp Run Slope (%)	6.6	N/A	Flare Slope LT (%)	4.6
Yes	Ramp Cross Slope (%)	0.5	N/A	Flare Traversable LT	Yes
N/A	Landing Present	Yes	N/A	Flare Type RT	
N/A	Landing Length (in)	68			Sloped
N/A	Landing Width (in)	62	N/A	Flare Slope RT (%)	7.1
N/A	Landing Run Slope (%)	2.4	N/A	Flare Traversable RT	Yes
N/A	Landing Cross Slope (%)	0.2	N/A	DWS Provided	Yes
N/A	Landing Movement Obstructed?	No	N/A	DWS Contrast	Yes
	Landing Movement Type	N/A	N/A	DWS Length (in)	36
N/A	Landing Shared	No	N/A	DWS Full Width	Yes
N/A	Clear Space	N/A	N/A	DWS Offset Left (in)	0
N/A	Clear Space To Crosswalk (in)	N/A	N/A	DWS Offset Right (in)	N/A
N/A	Marked Crosswalk 1	Yes	N/A	Marked Crosswalk 2	N/A
	Crossing 1 Direction	S		Crossing 2 Direction	N/A
	Marked Crosswalk 1 Width (in)	92		Marked Crosswalk 2 Width (in)	N/A
N/A	Ramp Inside Crosswalk 1	Yes	Yes	Ramp Inside Crosswalk 2	N/A
	Crossing 1 Slope (%)	5.4		Crossing 2 Slope (%)	N/A
	Crossing 1 Cross Slope (%)	0.9		Crossing 2 Cross Slope (%)	N/A
N/A	Gutter Ponding	No	Yes	Curb Slope	2.3
Yes	Gutter Lip Height (in)	0		Road Run Slope (%)	N/A
N/A	Gutter Run Slope (%)	6.5		Road Cross Slope (%)	N/A
N/A	Gutter Cross Slope (%)	0.6			
Yes	Overall Surface Condition: Acceptable		Yes	Perp Joint Present	Yes
	Cross Gutter Present?	No		Spandrel Present?	No
	Replace Cross Gutter?	N/A		Replace Spandrel?	N/A

