




Access Compliance Report Public Rights-of-Way (Pedestrian Signals)



Main Street: **IRVINE_AVE** Cross Street: **UNIVERSITY_DR** Location: **NW**

ADA ID: **SGRK211018112642** Signal Type: **One Push Button-Non APS** Overall Compliance: **No** Severity Scores: **BTN 1: 35** **BTN 2: N/A** **No BTN: N/A**

Codes/Mitigation Info/Possible Solution Field Measurements/Component Compliance



Possible Solutions: Replace Signal Push Button With APS Button. Remove and Replace Clear Space.

Surveyor Notes: Button 2 for Bike Lane

OC Std/PROW: R404.2, MUTCD 4e.08

Total Cost: \$ **1278**



APS Compliance

N/A Is Button 1 APS or Non-APS?	NonAPS	N/A Is Button 2 APS or Non-APS?	NonAPS
N/A B 1 VibroTact Arrow?	N/A	N/A B 2 VibroTact Arrow?	N/A
N/A B 1 VibroTact Parallel to Xing?	N/A	N/A B 2 VibroTact Parallel to Xing?	N/A
N/A B 1 VibroTact Contrast	N/A	N/A B 2 VibroTact Contrast	N/A
No B 1 Pilot Light?	No	N/A B 2 Pilot Light?	No
N/A B 1 Pilot Light Illumination?	N/A	N/A B 2 Pilot Light Illumination?	N/A
N/A B 1 Walk Indicator Type	N/A	N/A B 2 Walk Indicator Type	N/A
N/A B 1 Walk Indicator Audible?	N/A	N/A B 2 Walk Indicator Audible?	N/A
N/A B 1 Locator Tone?	N/A	N/A B 2 Locator Tone?	N/A
N/A B 1 Tone Audible Range?	N/A	N/A B 2 Tone Audible Range?	N/A
B 1 Addl APS Features?	No	B 2 Addl APS Features?	No
B 1 Addl APS Features Notes	N/A	B 2 Addl APS Features Notes	N/A

Compliance	Description	Data	Compliance	Description	Data
Button Count		Button1	Yes	Distant to Additional Button (in)	264
Additional Button Present?		Yes	N/A	Additional Button ID	SGRK211018112937
Located In An Island/Median?		No			
N/A B 1 Sign Present?		Yes	N/A	B 2 Sign Present?	Yes
Yes B 1 Sign Purpose?		Yes	N/A	B 2 Sign Purpose?	Yes
Yes B 1 Sign Lettering & Contrast?		Yes	N/A	B 2 Sign Lettering & Contrast?	Yes
Yes B 1 Parallel To XWalk?		Yes	N/A	B 2 Parallel To XWalk?	Yes
N/A B 1 PAR to Button?		N/A	N/A	B 2 PAR to Button?	N/A
N/A B 1 PAR to XWalk?		N/A	N/A	B 2 PAR to XWalk?	N/A
Yes B 1 Clear Floor Space?		Yes	N/A	B 2 Clear Floor Space?	Yes
N/A B 1 FWD Approach?		N/A	N/A	B 2 FWD Approach?	N/A
N/A B 1 FWD Approach Constrained?		N/A	N/A	B 2 FWD Approach Constrained?	N/A
N/A B 1 FWD Approach Reach (in)		N/A	N/A	B 2 FWD Approach Reach (in)	N/A
N/A B 1 FWD Approach Width (in)		N/A	N/A	B 2 FWD Approach Width (in)	N/A
N/A B 1 FWD Approach Obstruction?		N/A	N/A	B 2 FWD Approach Obstruction?	N/A
N/A B 1 FWD Approach Obstruction Dist (in)		N/A	N/A	B 2 FWD Approach ObstructionDist (in)	N/A
N/A B 1 PARA Approach?		N/A	N/A	B 2 PARA Approach?	N/A
N/A B 1 PARA Approach Constrained?		No	N/A	B 2 PARA Approach Constrained?	No
Yes B 1 PARA Approach Reach (in)		0	N/A	B 2 PARA Approach Reach (in)	0
N/A B 1 PARA Approach Width (in)		N/A	N/A	B 2 PARA Approach Width (in)	N/A
N/A B 1 PARA Approach Obstruction?		No	N/A	B 2 PARA Approach Obstruction?	No
N/A B 1 PARA Approach Obstruction Dist (in)		N/A	N/A	B 2 PARA Approach Obstruction Dist (in)	N/A
Yes B 1 Clear Floor Space Slope (%)		0.5	N/A	B 2 Clear Floor Space Slope (%)	0.5
No B 1 Clear Floor Space XSlope (%)		4.2	N/A	B 2 Clear Floor Space XSlope (%)	4.2
N/A B 1 PAR Slope (%)		3.7	N/A	B 2 PAR Slope (%)	3.7
Yes B 1 Height (in)		41	N/A	B 2 Height (in)	41
Yes B 1 Pressure (#)		5	N/A	B 2 Pressure (#)	5
Yes B 1 Closed Fist Operation?		Yes	N/A	B 2 Closed Fist Operation?	Yes
Yes B 1 Diameter (in)		2	N/A	B 2 Diameter (in)	2
N/A B 1 Crossing Direction		NE	N/A	B 2 Crossing Direction	SE
Yes B 1 DistanceTo XWalk (in)		10	N/A	B 2 DistanceTo XWalk (in)	10
Yes B 1 DistanceTo Curb (in)		24	N/A	B 2 DistanceTo Curb (in)	25

Parcel Identification Number **439-111-23**

Google Street View Link

http://www.google.com/maps/@?api=1&map_action=pano&viewpoint=33.65585329,-117.88735815