



Access Compliance Report Public Rights-of-Way (Pedestrian Signals)



Main Street: **VILLA_PARK_RD** Cross Street: **LEMON_ST** Location: **NW**

ADA ID: **SGRK211222142720** Signal Type: **One Push Button-Non APS** Overall Compliance: **No** Severity Scores: **BTN 1: 35** **BTN 2: N/A** **No BTN: N/A**

Codes/Mitigation Info/Possible Solution Field Measurements/Component Compliance




Possible Solutions: Replace Signal Push Button With APS Button. Remove & Relocate Sign.

Surveyor Notes: Button 2 for Bike Lane

OC Std/PROW: MUTCD 4e.08, R404.2, DMS-11132, R104.2, R209.1

Total Cost: \$ **650**



APS Compliance

N/A Is Button 1 APS or Non-APS?	NonAPS	N/A Is Button 2 APS or Non-APS?	NonAPS
N/A B 1 VibroTact Arrow?	N/A	N/A B 2 VibroTact Arrow?	N/A
N/A B 1 VibroTact Parallel to Xing?	N/A	N/A B 2 VibroTact Parallel to Xing?	N/A
N/A B 1 VibroTact Contrast	N/A	N/A B 2 VibroTact Contrast	N/A
No B 1 Pilot Light?	No	N/A B 2 Pilot Light?	No
N/A B 1 Pilot Light Illumination?	N/A	N/A B 2 Pilot Light Illumination?	N/A
N/A B 1 Walk Indicator Type	N/A	N/A B 2 Walk Indicator Type	N/A
N/A B 1 Walk Indicator Audible?	N/A	N/A B 2 Walk Indicator Audible?	N/A
N/A B 1 Locator Tone?	N/A	N/A B 2 Locator Tone?	N/A
N/A B 1 Tone Audible Range?	N/A	N/A B 2 Tone Audible Range?	N/A
B 1 Addl APS Features?	No	B 2 Addl APS Features?	No
B 1 Addl APS Features Notes	N/A	B 2 Addl APS Features Notes	N/A

Compliance	Description	Data	Compliance	Description	Data
Button Count		Button1	Yes	Distant to Additional Button (in)	450
Additional Button Present?		Yes	N/A	Additional Button ID	SGRK211222142959
Located In An Island/Median?		No			
N/A B 1 Sign Present?		Yes	N/A	B 2 Sign Present?	Yes
Yes B 1 Sign Purpose?		Yes	N/A	B 2 Sign Purpose?	Yes
Yes B 1 Sign Lettering & Contrast?		Yes	N/A	B 2 Sign Lettering & Contrast?	Yes
Yes B 1 Parallel To XWalk?		Yes	N/A	B 2 Parallel To XWalk?	Yes
N/A B 1 PAR to Button?		N/A	N/A	B 2 PAR to Button?	N/A
N/A B 1 PAR to XWalk?		N/A	N/A	B 2 PAR to XWalk?	N/A
Yes B 1 Clear Floor Space?		Yes	N/A	B 2 Clear Floor Space?	Yes
N/A B 1 FWD Approach?		N/A	N/A	B 2 FWD Approach?	N/A
N/A B 1 FWD Approach Constrained?		N/A	N/A	B 2 FWD Approach Constrained?	No
N/A B 1 FWD Approach Reach (in)		N/A	N/A	B 2 FWD Approach Reach (in)	20
N/A B 1 FWD Approach Width (in)		N/A	N/A	B 2 FWD Approach Width (in)	N/A
N/A B 1 FWD Approach Obstruction?		N/A	N/A	B 2 FWD Approach Obstruction?	No
N/A B 1 FWD Approach Obstruction Dist (in)		N/A	N/A	B 2 FWD Approach ObstructionDist (in)	N/A
N/A B 1 PARA Approach?		N/A	N/A	B 2 PARA Approach?	N/A
N/A B 1 PARA Approach Constrained?		No	N/A	B 2 PARA Approach Constrained?	N/A
Yes B 1 PARA Approach Reach (in)		0	N/A	B 2 PARA Approach Reach (in)	N/A
N/A B 1 PARA Approach Width (in)		N/A	N/A	B 2 PARA Approach Width (in)	N/A
N/A B 1 PARA Approach Obstruction?		No	N/A	B 2 PARA Approach Obstruction?	N/A
N/A B 1 PARA Approach Obstruction Dist (in)		N/A	N/A	B 2 PARA Approach Obstruction Dist (in)	N/A
Yes B 1 Clear Floor Space Slope (%)		0.1	N/A	B 2 Clear Floor Space Slope (%)	1.9
No B 1 Clear Floor Space XSlope (%)		2.1	N/A	B 2 Clear Floor Space XSlope (%)	0.5
N/A B 1 PAR Slope (%)		0.1	N/A	B 2 PAR Slope (%)	0.9
Yes B 1 Height (in)		48	N/A	B 2 Height (in)	48
Yes B 1 Pressure (#)		5	N/A	B 2 Pressure (#)	5
No B 1 Closed Fist Operation?		No	N/A	B 2 Closed Fist Operation?	No
No B 1 Diameter (in)		0.25	N/A	B 2 Diameter (in)	0.25
N/A B 1 Crossing Direction		E	N/A	B 2 Crossing Direction	S
No B 1 DistanceTo XWalk (in)		72	N/A	B 2 DistanceTo XWalk (in)	92
Yes B 1 DistanceTo Curb (in)		28	N/A	B 2 DistanceTo Curb (in)	24
Parcel Identification Number		378-081-30			
Google Street View Link					

http://www.google.com/maps/@?api=1&map_action=pano&viewpoint=33.81076851,-117.80900424